



CITY OF ORLANDO

Office of the Fire Marshal



	CODE SECTION	DESCRIPTION	CHANGES	Page #	Line #
1	Ordinance		Corrected spelling of the word fire safety	1 & 2	21, 23,37 & 2
2		Editors Note-	Changed the code edition to Fifth	2	17
3	24.01 (b) 7 & (16)	Scope	Added language to align with NFPA 1	3 & 4	7 & 11
4	24.02 (c) & (d)	Title	Removed the word Uniform	4	20 & 27
5	24.04 (h)	This Code shall be administered	Corrected the numbering sequence	6	14
6	24.08 (n) (1)	Authority/Stop Work or Evacuation	Added the word construction to align with NFPA 1	11	21
7	24.08 (n) (3) & (4)	Authority/Stop Work or Evacuation	Added language to align with NFPA 1	11	26 & 27
8	24.08 (n) (5)	Authority/Stop Work or Evacuation	Corrected the numbering sequence	11	28
9	24.08 (o) (1), (2) & (3)	Authority/Imminent Dangers and Evacuation	Added language to align with NFPA 1	11 & 12	30-35 & 1-2
10	24.08 (p) (1 -6)	Standby Fire Personnel	Corrected the numbering sequence	12	4,5,6,10,12-19,23 & 25-33
11	24.08 (p) (3 -6)	Standby Fire Personnel	Added language to align with NFPA 1	12	12-19 & 25-33
12	24.08 (q)	Public Fire Education	Corrected the numbering sequence	13	1 & 4
13	24.08 (q)	Public Fire Education	Added the word exclusively to align with NFPA 1	12	26
14	24.13 (c) (1) & (2)	Permits and Approvals/Conditions of Approval	Corrected the numbering sequence & Added language to align with NFPA 1	17	9-17, 25, 26, 30 & 32
15	24.13 (d), (f), (g), (h), (i) (9) & (j)	Permits and Approvals/Conditions of Approval	Corrected the numbering sequence & Added language to align with NFPA 1	17 - 22	Entire Section
16	24.15(a) (16), (17) & (18)	Plans Review and Inspections Fees	Corrected the numbering sequence and Added language to align with current OFD fee	22 -23	11 & 10-12
17	24.16	Technical Assistance	Corrected the numbering sequence	24	6
18	24.17(b)(1) (a) & (b)	Notice of Violations and Penalties	Corrected the numbering sequence	24	16-24
19	24.17 (b)(2),(a), (b) & (c)	Notice of Violations and Penalties/Serving Notice	Corrected the numbering sequence & Added language to align with NFPA 1	24	25-31
20	24.17 (b)(3)	Notice of Violations and Penalties/Serving Notice	Corrected the numbering sequence & Added language to align with NFPA 1	24	32-34
21	24.17 (c), (d), (e), (f), (g) & (h)	Notice of Violations and Penalties/Destruction or Removal of Notice	Corrected the numbering sequence & Added language to align with NFPA 1	25	3-20
22	24.24 (b) (4), (5) & (6)	General Safety Requirements/Responsibility to Prevent Overcrowding	Corrected the numbering sequence & Added language to align with NFPA 1	29 & 30	19-33 & 1-10
23	24.24 (d) (1) & (3)	General Safety Requirements/Tampering with Fire Safety Equipment	Corrected the numbering sequence & Added language to align with NFPA 1	30 & 31	30-35 & 10-11
24	24.25 (b) (1)	Testing of Emergency and Standby Power Supply	Removed the Exception to the rule	32	19 -20
25	24.27 (c) (1)	Fire Protection System/Automatic Fire Extinguishing System Required	Removed the four (4) hour fire resistance rated fire walls to two(2) hours	35	5
26	24.27 (c) (3)	Fire Protection System/ Automatic Fire Extinguishing System	Added "or change in use" for business rule clarification	35	24
27	24.30 (d)(1), (2),(3), (4) & (5)	Fire Department Access and Water Supply	Corrected the numbering sequence & Added language to align with NFPA 1 & Added " OFD Standard for Fire Department Access" for business rule clarification	36, 37 & 38	29-30, 14-34 & 1-11