


MADDEN

CIVIL ENGINEERS

31 E. Horatio Avenue
Suite 260
Maitland, Florida 32751
(407) 629-8330

OVERALL UTILITY PLAN
FOR
AMELIA COURT LIFT STATION
ORLANDO
FLORIDA

AMELIA COURT SOUTH PARTNERS, LTD
200 EAST CANTON AVENUE, SUITE 102
WINTER PARK, FL 32789
407-741-8666



1	8/24/17	
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
	DATE	REVISIONS

B # 15075
DATE: 09/05/17
SCALE: 1" = 60'
SIGNED BY: TRF
DRAWN BY: FAM
APPROVED BY: DAS

JT - 1

FDEP SEPARATION REQUIREMENTS UNDER 62-555.314 EFFECTIVE 8-28-2003				
HAZARD	HORIZONTAL SEPARATION	VERTICAL SEPARATION		JOINT SPACING
		WATER ABOVE	WATER BELOW	
STORM SEWER	3FT MIN	12IN PREF, 6IN MIN	12IN MIN	3FT MIN
STORM FORCE MAIN	3FT MIN	12IN MIN	12IN MIN	3FT MIN
RECLAIMED WATER IF REGULATED UNDER 62-610	3FT MIN	12IN MIN	12IN MIN	3FT MIN
RECLAIMED WATER IF NOT REGULATED UNDER 62-610	10FT PREF, 6FT MIN	12IN MIN	12IN MIN	6FT MIN
VACUUM SANITARY SEWER	10FT PREF, 3FT MIN	12IN PREF, 6IN MIN	12IN MIN	3FT MIN
GRAVITY SANITARY SEWER	10FT PREF, 6FT MIN, 3FT MIN IF WATER MAIN IS 6IN ABOVE GRAVITY SANITARY SEWER.	12IN PREF, 6IN MIN	12IN MIN	6FT MIN
SANITARY SEWER FORCE MAIN	10FT PREF, 6FT MIN	12IN MIN	12IN MIN	6FT MIN
SEWAGE TREATMENT & DISPOSAL SYSTEM	10FT MIN	NONE	NONE	NONE

UTILITY NOTES:

1. ALL EXISTING OVERHEAD UTILITIES SHALL BE COORDINATED WITH THE APPROPRIATE PROVIDER AND RELOCATED AS NECESSARY.
2. CONTRACTOR SHALL FIELD VERIFY LOCATIONS OF ALL EXISTING UTILITIES.
3. CONTRACTOR TO VERIFY LOCATION AND INVERT OF SEWER SERVICE TO BE USED.
4. EXISTING UTILITIES IN RIGHT-OF-WAY TO BE RELOCATED AS NECESSARY.